ENTERGY LOUISIANA, LLC
LOUISIANA PUBLIC SERVICE COMMISSION
UNDOCKETED WINTER STORM EVENT

Response of: Entergy Louisiana, LLC
to the First Set of Data Requests
of Requesting Party: Louisiana Public Service Commission

Question No.: LPSC 1-1 Part No.: Addendum:

Question:

How many MW of generation were offline or otherwise subject to unplanned outages during the Winter Storms?

Response:

The table below, presented at the March 11, 2021 Markets Subcommittee meeting of the Midcontinent Independent System Operator, Inc. ("MISO") provides the information requested for all of MISO South.



	February 14, 2021	February 15, 2021	February 16, 2021	February 17, 2021	February 18, 2021
Total unplanned	6.4 GW	13.6 GW	17.5 GW	18.0 GW	16.8 GW
Percentage of installed capacity** (41.3 GW)	16%	33%	42%	44%	41%

Fuel Mechanical Weather Other

Chart reflects data as it resided in the CROW Outage system on March 1, 2021